

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	5 <sup>th</sup> September 2018
Results Obtained	14 <sup>th</sup> September 2018
Results Published	19 <sup>th</sup> September 2018

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	<0.1
		Nitrogen (total)	0.11
		Oil and grease	<1
		pH	7.22
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	<0.1
		Nitrogen (total)	0.15
		Oil and grease	<1
		pH	7.26
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 <sup>th</sup> Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	25	30	Milligrams per litre
		Faecal Coliforms	116	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	39.6	3	Milligrams per litre
		Nitrogen (total)	42.3	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.57	6.5 – 8.5	pH
		Phosphorous (total)	1.38	0.5	Milligrams per litre
Total Suspended Solids	62	35	Milligrams per litre		
Comments					