

| | |
|--------------------|-----------------------------|
| Licensee | Perisher Blue Pty Ltd |
| EPL No | 2274 |
| Sampling Conducted | 7 th March 2018 |
| Results Obtained | 21 st March 2018 |
| Results Published | 21 st March 2018 |

| Monitoring Results | | | | | |
|---|---|---------------------------|-------------------|------------------------------------|----------------------|
| Monitoring Point | Monitoring Frequency | Pollutant | Monitoring Result | 100 th Percentile Limit | Unit |
| 3 – 20m upstream of discharge to waters | Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May | Biochemical oxygen demand | <2 | 30 | Milligrams per litre |
| | | Nitrogen (ammonia) | <0.1 | 3 | Milligrams per litre |
| | | Nitrogen (total) | 0.09 | 15 | Milligrams per litre |
| | | Oil and grease | <1 | 10 | Milligrams per litre |
| | | pH | 7.35 | 6.5 – 8.5 | pH |
| | | Phosphorous (total) | <0.01 | 0.5 | Milligrams per litre |
| | | Total Suspended Solids | <2 | 35 | Milligrams per litre |
| Comments | | | | | |

| Monitoring Results | | | | | |
|--|---|---------------------------|-------------------|------------------------------------|----------------------|
| Monitoring Point | Monitoring Frequency | Pollutant | Monitoring Result | 100 th Percentile Limit | Unit |
| 4 – 100m downstream of discharge to waters | Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May | Biochemical oxygen demand | <2 | 30 | Milligrams per litre |
| | | Nitrogen (ammonia) | <0.1 | 3 | Milligrams per litre |
| | | Nitrogen (total) | 0.14 | 15 | Milligrams per litre |
| | | Oil and grease | <1 | 10 | Milligrams per litre |
| | | pH | 7.43 | 6.5 – 8.5 | pH |
| | | Phosphorous (total) | <0.01 | 0.5 | Milligrams per litre |
| | | Total Suspended Solids | <2 | 35 | Milligrams per litre |
| Comments | | | | | |

| Monitoring Results | | | | | |
|-----------------------------------|---|---------------------------|-------------------|------------------------------------|--|
| Monitoring Point | Monitoring Frequency | Pollutant | Monitoring Result | 100 th Percentile Limit | Unit |
| 5 – Post UV disinfection facility | Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May | Biochemical oxygen demand | <2 | 30 | Milligrams per litre |
| | | Faecal Coliforms | <1 | 600 | Colony forming units per 100 millilitres |
| | | Nitrogen (ammonia) | <0.1 | 3 | Milligrams per litre |
| | | Nitrogen (total) | 0.60 | 15 | Milligrams per litre |
| | | Oil and grease | <1 | 10 | Milligrams per litre |
| | | pH | 7.82 | 6.5 – 8.5 | pH |
| | | Phosphorous (total) | 0.07 | 0.5 | Milligrams per litre |
| | | Total Suspended Solids | 2 | 35 | Milligrams per litre |
| Comments | | | | | |