

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	18 th September 2019
Results Obtained	27 th September 2019
Results Published	30 th September 2019

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	0.005
		Nitrogen (total)	0.16
		Oil and grease	<1
		pH	7.11
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	0.004
		Nitrogen (total)	0.16
		Oil and grease	<1
		pH	6.99
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	2.28	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	8.03	6.5 – 8.5	pH
		Phosphorous (total)	0.05	0.5	Milligrams per litre
Comments					