

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	1 <sup>st</sup> Nov 2023
Results Obtained	14 <sup>th</sup> Month 2023
Results Published	16 <sup>th</sup> Month 2023

Monitoring Point	Pollutant								Monitoring Frequency
	Biochemical oxygen demand	Faecal Coliforms	Nitrogen (ammonia)	Nitrogen (total)	Oil and grease	pH	Phosphorous (total)	Total Suspended Solids	
	Milligrams per litre	CFU per 100 millilitres	Milligrams per litre	Milligrams per litre	Milligrams per litre	pH	Milligrams per litre	Milligrams per litre	
3 – 20m upstream of discharge to waters	<2	13	0.007	0.07	<1	7.37	<0.01	<2	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May
4 – 100m downstream of discharge to waters	2	16	<0.002	0.07	<1	7.14	<0.01	12	
5 – Post UV disinfection facility	2	<2	<0.001	0.27	<1	7.32	0.03	<2	
<i>Point 5 - 100% concentration limit</i>	<i>30</i>	<i>600</i>	<i>3</i>	<i>15</i>	<i>10</i>	<i>6.5-8.5</i>	<i>0.5</i>	<i>35</i>	
6 – Weir at the end of Wetland System	<2	<1	0.004	0.11	1	7.11	<0.01	<2	
Notes:									