

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	16 th September 2020
Results Obtained	24 th September
Results Published	27 th September 2020

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
3 – 20m upstream of discharge to waters	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Faecal Coliforms	3
		Nitrogen (ammonia)	<0.002
		Nitrogen (total)	0.09
		Oil and grease	<1
		pH	7.59
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
4 – 100m downstream of discharge to waters	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Faecal Coliforms	1
		Nitrogen (ammonia)	0.002
		Nitrogen (total)	0.09
		Oil and grease	<1
		pH	7.54
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.81	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.58	6.5 – 8.5	pH
		Phosphorous (total)	0.02	0.5	Milligrams per litre
		Total Suspended Solids	<2	35	Milligrams per litre
Comments					