Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	16 <sup>th</sup> April 2025
Results Obtained	29 <sup>th</sup> April 2025
Results Published	30 <sup>th</sup> April 2025

	Pollutant								
Monitoring Point	Biochemical oxygen demand	Faecal Coliforms	Nitrogen (ammonia)	Nitrogen (total)	Oil and grease	рН	Phosphorous (total)	Total Suspended Solids	Monitoring Frequency
	Milligrams per litre	CFU per 100 millitres	Milligrams per litre	Milligrams per litre	Milligrams per litre	рН	Milligrams per litre	Milligrams per litre	
3 – 20m upstream of discharge to waters	<2	66	0.004	0.09	<1	7.16	<0.01	<2	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May
4 – 100m downstream of discharge to waters	<2	54	0.003	0.09	<1	7.18	<0.01	<2	
5 – Post UV disinfection facility	<2	<2	1	3.19	<1	8.18	0.08	13	
Point 5 - 100% concentration limit	30	600	3	15	10	6.5-8.5	0.5	35	
6 – Weir at the end of Wetland System	<2	2	0.013	0.24	<1	7.46	0.02	<2	
Notes:							'	1	