Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	24-Jun-26
Results Obtained	2nd Jul 2026
Results Published	2nd Jul 2026

Monitoring Point	Pollutant								Monitoring Frequency
	Biochemical oxygen demand	**Faecal Coliforms**	**Nitrogen (ammonia)**	**Nitrogen (total)**	**Oil and grease**	**pH**	**Phosphorous (total)**	**Total Suspended Solids**	
	Milligrams per litre	CFU per 100 millitres	Milligrams per litre	Milligrams per litre	Milligrams per litre	pH	Milligrams per litre	Milligrams per litre	
3 – 20m upstream of discharge to waters	<2	1	<0.1	0.15	<1	7.24	0.02	<2	Fortnightly between June 1 and 30 September, and quarterly between 1 October and 31 May
4 – 100m downstream of discharge to waters	<2	2	0.1	0.14	<1	7.02	0.01	<2	
5 – Post UV disinfection facility	5	<1	<0.1	6.46	<1	7.78	0.06	<2	
Point 5 - 100% concentration limit	**30**	**600**	**3**	**15**	**10**	**6.5-8.5**	**0.5**	**35**	
6 – Weir at the end of Wetland System	<2	<1	<0.1	0.24	<1	7.08	0.03	<2	
Notes:									