

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	10/05/2017
Results Obtained	19/05/2017
Results Published	25/07/2017

Monitoring Results

Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.09	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.15	6.5 – 8.5	pH
		Phosphorous (total)	<0.01	0.5	Milligrams per litre
		Total Suspended Solids	<2	35	Milligrams per litre
Comments					

Monitoring Results

Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.08	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.26	6.5 – 8.5	pH
		Phosphorous (total)	<0.01	0.5	Milligrams per litre
		Total Suspended Solids	<2	35	Milligrams per litre
Comments					

Monitoring Results

Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	3	30	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	0.3	3	Milligrams per litre
		Nitrogen (total)	1.46	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.36	6.5 – 8.5	pH
		Phosphorous (total)	0.06	0.5	Milligrams per litre
Total Suspended Solids	8	35	Milligrams per litre		
Comments					