

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	6 <sup>th</sup> March 2019
Results Obtained	23 <sup>rd</sup> March 2019
Results Published	1 <sup>st</sup> May 2019

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	<0.1
		Nitrogen (total)	0.16
		Oil and grease	<1
		pH	7.4
		Phosphorous (total)	0.01
		Total Suspended Solids	6
Comments			

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	<0.1
		Nitrogen (total)	0.17
		Oil and grease	<1
		pH	7.4
		Phosphorous (total)	0.01
		Total Suspended Solids	4
Comments			

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 <sup>th</sup> Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	0.2	3	Milligrams per litre
		Nitrogen (total)	0.76	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.84	6.5 – 8.5	pH
		Phosphorous (total)	0.02	0.5	Milligrams per litre
Total Suspended Solids	2	35	Milligrams per litre		
Comments					