

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	26/07/2017
Results Obtained	03/08/2017
Results Published	06/08/2017

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.20	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	6.98	6.5 – 8.5	pH
		Phosphorous (total)	0.01	0.5	Milligrams per litre
		Total Suspended Solids	6	35	Milligrams per litre
Comments					

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.23	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	6.97	6.5 – 8.5	pH
		Phosphorous (total)	0.01	0.5	Milligrams per litre
		Total Suspended Solids	5	35	Milligrams per litre
Comments					

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	34	30	Milligrams per litre
		Faecal Coliforms	44	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	12.6	3	Milligrams per litre
		Nitrogen (total)	22.2	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.21	6.5 – 8.5	pH
		Phosphorous (total)	1.43	0.5	Milligrams per litre
Total Suspended Solids	85	35	Milligrams per litre		
Comments					