

MONITORING RESULTS

Licensee:	Perisher Blue Pty Ltd
EPL No.	2274
Sampling Conducted:	12-November-2014
Results Obtained:	20-November-2014
Results Published:	12-January-2015

Monitoring Point	Monitoring frequency required by licence	Pollutant	Monitoring Result	Unit
3 (20 metres upstream of Discharge to Waters)	Monthly between 1 June and 30 September and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	milligrams per litre
		Nitrogen (ammonia)	<0.1	milligrams per litre
		Nitrogen (total)	0.7	milligrams per litre
		Oil and Grease	<0.1	milligrams per litre
		pH	7.18	pH
		Phosphorous (total)	<0.01	milligrams per litre
		Total suspended solids	<2	milligrams per litre

Comments:	No comments.
-----------	--------------

Monitoring Point	Monitoring frequency required by licence	Pollutant	Monitoring Result	Unit
4 (100 metres downstream of Discharge to Waters)	Monthly between 1 June and 30 September and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	milligrams per litre
		Nitrogen (ammonia)	<0.1	milligrams per litre
		Nitrogen (total)	0.08	milligrams per litre
		Oil and Grease	<1	milligrams per litre
		pH	7.2	pH
		Phosphorous (total)	<0.01	milligrams per litre
		Total suspended solids	<2	milligrams per litre

Comments:	No comments.
-----------	--------------

Monitoring Point	Monitoring frequency required by licence	Pollutant	Monitoring Result	90 th Percentile Limit	100 th Percentile Limit	Unit
5 (Post-UV disinfection facility)	Monthly between 1 June and 30 September and quarterly between 1 October and 31 May	Biochemical oxygen demand	3	10	30	milligrams per litre
		Faecal coliforms	<1	200	600	colony forming units per 100 millilitres
		Nitrogen (ammonia)	0.2	2	3	milligrams per litre
		Nitrogen (total)	1.29	10	15	milligrams per litre
		Oil and Grease	<1	2	10	milligrams per litre
		pH	7.57	6.5-8.5	6.5-8.5	pH
		Phosphorous (total)	0.03	0.3	0.5	milligrams per litre
Total suspended solids	<2	15	35	milligrams per litre		

Comments:	No comments.
-----------	--------------