

|                    |                       |
|--------------------|-----------------------|
| Licensee           | Perisher Blue Pty Ltd |
| EPL No             | 2274                  |
| Sampling Conducted | 22/07/2015            |
| Results Obtained   | 30/07/2015            |
| Results Published  | 1/08/2015             |

| Monitoring Results                      |   |                           |                   |                                    |                      |
|---|---|---------------------------|-------------------|------------------------------------|----------------------|
| Monitoring Point                        | Monitoring Frequency  | Pollutant                 | Monitoring Result | 100 <sup>th</sup> Percentile Limit | Unit                 |
| 3 – 20m upstream of discharge to waters | Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May | Biochemical oxygen demand | <2                | 30                                 | Milligrams per litre |
|   |   | Nitrogen (ammonia)        | <0.1              | 3                                  | Milligrams per litre |
|   |   | Nitrogen (total)          | 0.08              | 15                                 | Milligrams per litre |
|   |   | Oil and grease            | <1                | 10                                 | Milligrams per litre |
|   |   | pH                        | 7.46              | 6.5 – 8.5                          | pH                   |
|   |   | Phosphorous (total)       | <0.01             | 0.5                                | Milligrams per litre |
|   |   | Total Suspended Solids    | <2                | 35                                 | Milligrams per litre |
| Comments                                |   |                           |                   |                                    |                      |

| Monitoring Results                         |   |                           |                   |                                    |                      |
|--|---|---------------------------|-------------------|------------------------------------|----------------------|
| Monitoring Point                           | Monitoring Frequency  | Pollutant                 | Monitoring Result | 100 <sup>th</sup> Percentile Limit | Unit                 |
| 4 – 100m downstream of discharge to waters | Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May | Biochemical oxygen demand | <2                | 30                                 | Milligrams per litre |
|  |   | Nitrogen (ammonia)        | <0.1              | 3                                  | Milligrams per litre |
|  |   | Nitrogen (total)          | 0.09              | 15                                 | Milligrams per litre |
|  |   | Oil and grease            | <1                | 10                                 | Milligrams per litre |
|  |   | pH                        | 7.30              | 6.5 – 8.5                          | pH                   |
|  |   | Phosphorous (total)       | <0.01             | 0.5                                | Milligrams per litre |
|  |   | Total Suspended Solids    | <2                | 35                                 | Milligrams per litre |
| Comments                                   |   |                           |                   |                                    |                      |

| Monitoring Results                |   |                           |                   |                                    |  |
|-----------------------------------|---|---------------------------|-------------------|------------------------------------|--|
| Monitoring Point                  | Monitoring Frequency  | Pollutant                 | Monitoring Result | 100 <sup>th</sup> Percentile Limit | Unit                                     |
| 5 – Post UV disinfection facility | Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May | Biochemical oxygen demand | 25                | 30                                 | Milligrams per litre                     |
|                                   |   | Faecal Coliforms          | <2                | 600                                | Colony forming units per 100 millilitres |
|                                   |   | Nitrogen (ammonia)        | 3                 | 3                                  | Milligrams per litre                     |
|                                   |   | Nitrogen (total)          | 7.78              | 15                                 | Milligrams per litre                     |
|                                   |   | Oil and grease            | <1                | 10                                 | Milligrams per litre                     |
|                                   |   | pH                        | 7.25              | 6.5 – 8.5                          | pH                                       |
|                                   |   | Phosphorous (total)       | 0.56              | 0.5                                | Milligrams per litre                     |
|                                   |   | Total Suspended Solids    | 46                | 35                                 | Milligrams per litre                     |
| Comments                          |   |                           |                   |                                    |  |