

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	14/01/2015
Results Obtained	22/01/2015
Results Published	01/06/2015

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	pH	6.94	6.5-8.5	pH
		Total Suspended Solids	8	35	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		Biological oxygen demand	<2	30	Milligrams per litre
		Ammonia	<0.1	3	
		Total Nitrogen	0.26	15	Milligrams per litre
		Total Phosphorous	0.02	0.5	Milligrams per litre
Comments	No comments				

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	pH	6.94	6.5-8.5	pH
		Total Suspended Solids	5	35	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		Biological oxygen demand	<2	30	Milligrams per litre
		Ammonia	<0.1	3	Milligrams per litre
		Total Nitrogen	0.24	15	Milligrams per litre
		Total Phosphorous	0.01	0.5	Milligrams per litre
Comments	No comments				

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	pH	7.88	6.5-8.5	pH
		Total Suspended Solids	<2	35	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		Biological oxygen demand	<2	30	Milligrams per litre
		Ammonia	0.1	3	Milligrams per litre
		Total Nitrogen	0.96	15	
		Total Phosphorous	0.05	0.5	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
Comments	No comments				