

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	12/03/2015
Results Obtained	24/03/2015
Results Published	01/06/2015

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	pH	7.36	6.5-8.5	pH
		Total Suspended Solids	<2	35	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		Biological oxygen demand	<2	30	Milligrams per litre
		Ammonia	<0.1	3	
		Total Nitrogen	0.18	15	Milligrams per litre
		Total Phosphorous	<0.01	0.5	Milligrams per litre
Comments	No comments				

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	pH	7.35	6.5-8.5	pH
		Total Suspended Solids	<2	35	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		Biological oxygen demand	<2	30	Milligrams per litre
		Ammonia	<0.1	3	Milligrams per litre
		Total Nitrogen	0.07	15	Milligrams per litre
		Total Phosphorous	<0.01	0.5	Milligrams per litre
Comments	No comments				

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	pH	7.86	6.5-8.5	pH
		Total Suspended Solids	<2	35	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		Biological oxygen demand	<2	30	Milligrams per litre
		Ammonia	0.2	3	Milligrams per litre
		Total Nitrogen	0.64	15	
		Total Phosphorous	0.05	0.5	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
Comments	No comments				