

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	10/08/16
Results Obtained	19/08/16
Results Published	26/08/16

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 <sup>th</sup> Percentile Limit	Unit
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.19	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.06	6.5 – 8.5	pH
		Phosphorous (total)	0.01	0.5	Milligrams per litre
		Total Suspended Solids	10	35	Milligrams per litre

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 <sup>th</sup> Percentile Limit	Unit
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.22	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.10	6.5 – 8.5	pH
		Phosphorous (total)	0.01	0.5	Milligrams per litre
		Total Suspended Solids	11	35	Milligrams per litre

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 <sup>th</sup> Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	4	30	Milligrams per litre
		Faecal Coliforms	<2	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	3.4	3	Milligrams per litre
		Nitrogen (total)	4.48	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.04	6.5 – 8.5	pH
		Phosphorous (total)	0.17	0.5	Milligrams per litre
Total Suspended Solids	8	35	Milligrams per litre		