

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	06/12/2017
Results Obtained	14/12/2017
Results Published	22/12/2017

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.11	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.09	6.5 – 8.5	pH
		Phosphorous (total)	<0.01	0.5	Milligrams per litre
		Total Suspended Solids	<2	35	Milligrams per litre
Comments					

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2	30	Milligrams per litre
		Nitrogen (ammonia)	<0.1	3	Milligrams per litre
		Nitrogen (total)	0.12	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.06	6.5 – 8.5	pH
		Phosphorous (total)	<0.01	0.5	Milligrams per litre
		Total Suspended Solids	<2	35	Milligrams per litre
Comments					

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	12	30	Milligrams per litre
		Faecal Coliforms	<1	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	7.7	3	Milligrams per litre
		Nitrogen (total)	10	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.48	6.5 – 8.5	pH
		Phosphorous (total)	0.23	0.5	Milligrams per litre
Total Suspended Solids	9	35	Milligrams per litre		
Comments					