

Licensee	Perisher Blue Pty Ltd
EPL No	2274
Sampling Conducted	8 th August 2018
Results Obtained	21 st August 2018
Results Published	4 th September 2018

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
3 – 20m upstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	<0.1
		Nitrogen (total)	0.10
		Oil and grease	<1
		pH	7.13
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results			
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result
4 – 100m downstream of discharge to waters	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	<2
		Nitrogen (ammonia)	<0.1
		Nitrogen (total)	0.12
		Oil and grease	<1
		pH	7.15
		Phosphorous (total)	<0.01
		Total Suspended Solids	<2
Comments			

Monitoring Results					
Monitoring Point	Monitoring Frequency	Pollutant	Monitoring Result	100 th Percentile Limit	Unit
5 – Post UV disinfection facility	Monthly between June 1 and 30 September, and quarterly between 1 October and 31 May	Biochemical oxygen demand	8	30	Milligrams per litre
		Faecal Coliforms	<2	600	Colony forming units per 100 millilitres
		Nitrogen (ammonia)	16.2	3	Milligrams per litre
		Nitrogen (total)	19.6	15	Milligrams per litre
		Oil and grease	<1	10	Milligrams per litre
		pH	7.65	6.5 – 8.5	pH
		Phosphorous (total)	0.44	0.5	Milligrams per litre
Total Suspended Solids	14	35	Milligrams per litre		
Comments					